

Rules for the Type Approval of Fixed Aerosol Fire-Extinguishing Systems in Machinery Spaces

Effective from 1 January 2021

GENERAL CONDITIONS

Definitions:

"Administration" means the Government of the State whose flag the Ship is entitled to fly or under whose authority the Ship is authorised to operate in the specific case.

"IACS" means the International Association of Classification Societies.

"Interested Party" means the party, other than the Society, having an interest in or responsibility for the Ship, product, plant or system subject to classification or certification (such as the owner of the Ship and his representatives, the ship builder, the engine builder or the supplier of parts to be tested) who requests the Services or on whose behalf the Services are requested.

"Owner" means the registered owner, the ship owner, the manager or any other party with the responsibility, legally or contractually, to keep the ship seaworthy or in service, having particular regard to the provisions relating to the maintenance of class laid down in Part A, Chapter 2 of the Rules for the Classification of Ships or in the corresponding rules indicated in the specific Rules.

"Rules" in these General Conditions means the documents below issued by the Society:

- (i) Rules for the Classification of Ships or other special units;
- (ii) Complementary Rules containing the requirements for product, plant, system and other certification or containing the requirements for the assignment of additional class notations;
- (iii) Rules for the application of statutory rules, containing the rules to perform the duties delegated by Administrations;
- (iv) Guides to carry out particular activities connected with Services;
- (v) Any other technical document, as for example rule variations or interpretations.

"Services" means the activities described in Article 1 below, rendered by the Society upon request made by or on behalf of the Interested Party.

"Ship" means ships, boats, craft and other special units, as for example offshore structures, floating units and underwater craft.

"Society" or "TASNEEF" means Tasneef and/or all the companies in the Tasneef Group which provide the Services.

"Surveyor" means technical staff acting on behalf of the Society in performing the Services.

Article 1

1.1. The purpose of the Society is, among others, the classification and certification of ships and the certification of their parts and components. In particular, the Society:

- (i) sets forth and develops Rules;
- (ii) publishes the Register of Ships;
- (iii) issues certificates, statements and reports based on its survey activities.

1.2. The Society also takes part in the implementation of national and international rules and standards as delegated by various Governments.

1.3. The Society carries out technical assistance activities on request and provides special services outside the scope of classification, which are regulated by these general conditions, unless expressly excluded in the particular contract.

Article 2

2.1. The Rules developed by the Society reflect the level of its technical knowledge at the time they are published. Therefore, the Society, although committed also through its research and development services to continuous updating of the Rules, does not guarantee the Rules meet state-of-the-art science and technology at the time of publication or that they meet the Society's or others' subsequent technical developments.

2.2. The Interested Party is required to know the Rules on the basis of which the Services are provided. With particular reference to Classification Services, special attention is to be given to the Rules concerning class suspension, withdrawal and reinstatement. In case of doubt or inaccuracy, the Interested Party is to promptly contact the Society for clarification.

The Rules for Classification of Ships are published on the Society's website: www.tasneef.ae.

2.3. The Society exercises due care and skill:

- (i) in the selection of its Surveyors
- (ii) in the performance of its Services, taking into account the level of its technical knowledge at the time the Services are performed.

2.4. Surveys conducted by the Society include, but are not limited to, visual inspection and non-destructive testing. Unless otherwise required, surveys are conducted through sampling techniques and do not consist of comprehensive verification or monitoring of the Ship or of the items subject to certification. The surveys and checks made by the Society on board ship do not necessarily require the constant and continuous presence of the Surveyor. The Society may also commission laboratory testing, underwater inspection and other checks carried out by and under the responsibility of qualified service suppliers. Survey practices and procedures are selected by the Society based on its experience and knowledge and according to generally accepted technical standards in the sector.

Article 3

3.1. The class assigned to a Ship, like the reports, statements, certificates or any other document or information issued by the Society, reflects the opinion of the Society concerning compliance, at the time the Service is provided, of the Ship or product subject to certification, with the applicable Rules (given the intended use and within the relevant time frame).

The Society is under no obligation to make statements or provide information about elements or facts which are not part of the specific scope of the Service requested by the Interested Party or on its behalf.

3.2. No report, statement, notation on a plan, review, Certificate of Classification, document or information issued or given as part of the Services provided by the Society shall have any legal effect or implication other than a representation that, on the basis of the checks made by the Society, the Ship, structure, materials, equipment, machinery or any other item covered by such document or information meet the Rules. Any such document is issued solely for the use of the Society, its committees and clients or other duly authorised bodies and for no other purpose. Therefore, the Society cannot be held liable for any act made or document issued by other parties on the basis of the statements or information given by the Society. The validity, application, meaning and interpretation of a Certificate of Classification, or any other document or information issued by the Society in connection with its Services, is governed by the Rules of the Society, which is the sole subject entitled to make such interpretation. Any disagreement on technical matters between the Interested Party and the Surveyor in the carrying out of his functions shall be raised in writing as soon as possible with the Society, which will settle any divergence of opinion or dispute.

3.3. The classification of a Ship, or the issuance of a certificate or other document connected with classification or certification and in general with the performance of Services by the Society shall have the validity conferred upon it by the Rules of the Society at the time of the assignment of class or issuance of the certificate; in no case shall it amount to a statement or warranty of seaworthiness,

structural integrity, quality or fitness for a particular purpose or service of any Ship, structure, material, equipment or machinery inspected or tested by the Society.

3.4. Any document issued by the Society in relation to its activities reflects the condition of the Ship or the subject of certification or other activity at the time of the check.

3.5. The Rules, surveys and activities performed by the Society, reports, certificates and other documents issued by the Society are in no way intended to replace the duties and responsibilities of other parties such as Governments, designers, ship builders, manufacturers, repairers, suppliers, contractors or sub-contractors, Owners, operators, charterers, underwriters, sellers or intended buyers of a Ship or other product or system surveyed.

These documents and activities do not relieve such parties from any fulfilment, warranty, responsibility, duty or obligation (also of a contractual nature) expressed or implied or in any case incumbent on them, nor do they confer on such parties any right, claim or cause of action against the Society. With particular regard to the duties of the ship Owner, the Services undertaken by the Society do not relieve the Owner of his duty to ensure proper maintenance of the Ship and ensure seaworthiness at all times. Likewise, the Rules, surveys performed, reports, certificates and other documents issued by the Society are intended neither to guarantee the buyers of the Ship, its components or any other surveyed or certified item, nor to relieve the seller of the duties arising out of the law or the contract, regarding the quality, commercial value or characteristics of the item which is the subject of transaction.

In no case, therefore, shall the Society assume the obligations incumbent upon the above-mentioned parties, even when it is consulted in connection with matters not covered by its Rules or other documents.

In consideration of the above, the Interested Party undertakes to relieve and hold harmless the Society from any third party claim, as well as from any liability in relation to the latter concerning the Services rendered.

Insofar as they are not expressly provided for in these General Conditions, the duties and responsibilities of the Owner and Interested Parties with respect to the services rendered by the Society are described in the Rules applicable to the specific Service rendered.

Article 4

4.1. Any request for the Society's Services shall be submitted in writing and signed by or on behalf of the Interested Party. Such a request will be considered irrevocable as soon as received by the Society and shall entail acceptance by the applicant of all relevant requirements of the Rules, including these General Conditions. Upon acceptance of the written request by the Society, a contract between the Society and the Interested Party is entered into, which is regulated by the present General Conditions.

4.2. In consideration of the Services rendered by the Society, the Interested Party and the person requesting the service shall be jointly liable for the payment of the relevant fees, even if the service is not concluded for any cause not pertaining to the Society. In the latter case, the Society shall not be held liable for non-fulfilment or partial fulfilment of the Services requested. In the event of late payment, interest at the legal current rate increased by 1.5% may be demanded.

4.3. The contract for the classification of a Ship or for other Services may be terminated and any certificates revoked at the request of one of the parties, subject to at least 30 days' notice to be given in writing. Failure to pay, even in part, the fees due for Services carried out by the Society will entitle the Society to immediately terminate the contract and suspend the Services.

For every termination of the contract, the fees for the activities performed until the time of the termination shall be owed to the Society as well as the expenses incurred in view of activities already programmed; this is without prejudice to the right to compensation due to the Society as a consequence of the termination.

With particular reference to Ship classification and certification, unless decided otherwise by the Society, termination of the contract implies that the assignment of class to a Ship is withheld or, if already assigned, that it is suspended or withdrawn; any statutory certificates issued by the Society will be withdrawn in those cases where provided for by agreements between the Society and the flag State.

Article 5

5.1. In providing the Services, as well as other correlated information or advice, the Society, its Surveyors, servants or agents operate with due diligence for the proper execution of the activity. However, considering the nature of the activities performed (see art. 2.4), it is not possible to guarantee absolute accuracy, correctness and completeness of any information or advice supplied. Express and implied warranties are specifically disclaimed.

Therefore, except as provided for in paragraph 5.2 below, and also in the case of activities carried out by delegation of Governments, neither the Society nor any of its Surveyors will be liable for any loss, damage or expense of whatever nature sustained by any person, in tort or in contract, derived from carrying out the Services.

5.2. Notwithstanding the provisions in paragraph 5.1 above, should any user of the Society's Services prove that he has suffered a loss or damage due to any negligent act or omission of the Society, its Surveyors, servants or agents, then the Society will pay compensation to such person for his proved loss, up to, but not exceeding, five times the amount of the fees charged for the specific services, information or opinions from which the loss or damage derives or, if no fee has been charged, a maximum of AED5,000 (Arab Emirates Dirhams Five Thousand only). Where the fees charged are related to a number of Services, the amount of the fees will be apportioned for the purpose of the calculation of the maximum compensation, by reference to the estimated time involved in the performance of the Service from which the damage or loss derives. Any liability for indirect or consequential loss, damage or expense is specifically excluded. In any case, irrespective of the amount of the fees charged, the maximum damages payable by the Society will not be more than AED5,000,000 (Arab Emirates Dirhams Five Millions only). Payment of compensation under this paragraph will not entail any admission of responsibility and/or liability by the Society and will be made without prejudice to the disclaimer clause contained in paragraph 5.1 above.

5.3. Any claim for loss or damage of whatever nature by virtue of the provisions set forth herein shall be made to the Society in writing, within the shorter of the following periods: (i) THREE (3) MONTHS from the date on which the Services were performed, or (ii) THREE (3) MONTHS from the date on which the damage was discovered. Failure to comply with the above deadline will constitute an absolute bar to the pursuit of such a claim against the Society.

Article 6

6.1. These General Conditions shall be governed by and construed in accordance with United Arab Emirates (UAE) law, and any dispute arising from or in connection with the Rules or with the Services of the Society, including any issues concerning responsibility, liability or limitations of liability of the Society, shall be determined in accordance with UAE law. The courts of the Dubai International Financial Centre (DIFC) shall have exclusive jurisdiction in relation to any claim or dispute which may arise out of or in connection with the Rules or with the Services of the Society.

6.2. However,

- (i) In cases where neither the claim nor any counterclaim exceeds the sum of AED300,000 (Arab Emirates Dirhams Three Hundred Thousand) the dispute shall be referred to the jurisdiction of the DIFC Small Claims Tribunal; and
- (ii) for disputes concerning non-payment of the fees and/or expenses due to the Society for services, the Society shall have the

right to submit any claim to the jurisdiction of the Courts of the place where the registered or operating office of the Interested Party or of the applicant who requested the Service is located.

In the case of actions taken against the Society by a third party before a public Court, the Society shall also have the right to summon the Interested Party or the subject who requested the Service before that Court, in order to be relieved and held harmless according to art. 3.5 above.

Article 7

7.1. All plans, specifications, documents and information provided by, issued by, or made known to the Society, in connection with the performance of its Services, will be treated as confidential and will not be made available to any other party other than the Owner without authorisation of the Interested Party, except as provided for or required by any applicable international, European or domestic legislation, Charter or other IACS resolutions, or order from a competent authority. Information about the status and validity of class and statutory certificates, including transfers, changes, suspensions, withdrawals of class, recommendations/conditions of class, operating conditions or restrictions issued against classed ships and other related information, as may be required, may be published on the website or released by other means, without the prior consent of the Interested Party.

Information about the status and validity of other certificates and statements may also be published on the website or released by other means, without the prior consent of the Interested Party.

7.2. Notwithstanding the general duty of confidentiality owed by the Society to its clients in clause 7.1 above, the Society's clients hereby accept that the Society may participate in the IACS Early Warning System which requires each Classification Society to provide other involved Classification Societies with relevant technical information on serious hull structural and engineering systems failures, as defined in the IACS Early Warning System (but not including any drawings relating to the ship which may be the specific property of another party), to enable such useful information to be shared and used to facilitate the proper working of the IACS Early Warning System. The Society will provide its clients with written details of such information sent to the involved Classification Societies.

7.3. In the event of transfer of class, addition of a second class or withdrawal from a double/dual class, the Interested Party undertakes to provide or to permit the Society to provide the other Classification Society with all building plans and drawings, certificates, documents and information relevant to the classed unit, including its history file, as the other Classification Society may require for the purpose of classification in compliance with the applicable legislation and relative IACS Procedure. It is the Owner's duty to ensure that, whenever required, the consent of the builder is obtained with regard to the provision of plans and drawings to the new Society, either by way of appropriate stipulation in the building contract or by other agreement.

In the event that the ownership of the ship, product or system subject to certification is transferred to a new subject, the latter shall have the right to access all pertinent drawings, specifications, documents or information issued by the Society or which has come to the knowledge of the Society while carrying out its Services, even if related to a period prior to transfer of ownership.

Article 8

8.1. Should any part of these General Conditions be declared invalid, this will not affect the validity of the remaining provisions.



RULES FOR THE TYPE APPROVAL OF FIXED AEROSOL FIRE-EXTINGUISHING SYSTEMS IN MACHINERY SPACES

Chapters **1 2 3 4**

Chapter 1	General Requirements for Approval
Chapter 2	Test Method for Systems of Ships Having a Length ≤ 24 m and with Machinery Spaces ≤ 140 m³
Chapter 3	Test Method for Systems of Ships Having a Length > 24 m or Machinery Spaces > 140 m³
Chapter 4	Test Method for Determination of Aerosol Generator Efficiency Coefficient

CHAPTER 1

GENERAL REQUIREMENTS FOR APPROVAL

1	General	7
	1.1	Premise
	1.2	Field of application
	1.3	Documentation
	1.4	Issue and validity of the type approval certificate
	1.5	Renewal of the type approval certificate
	1.6	Repetition of the tests
2	Definition	8
	2.1	
3	Principal Requirements	8
	3.1	General
	3.2	Condensed aerosol systems
	3.3	Dispersed aerosols systems
	3.4	System and components

CHAPTER 2

TEST METHOD FOR SYSTEMS OF SHIPS HAVING A LENGTH ≤ 24 M AND WITH MACHINERY SPACES ≤ 140 M³

1	Fire test method for fixed aerosol fire-extinguishing systems of ships having a length L not exceeding 24 m and machinery spaces having a gross volume not exceeding 140 m ³	11
	1.1 Scope	
	1.2 ce criteria	
2	Sampling	11
	2.1	
3	Method of test	11
	3.1 Test Room	
	3.2 Integrity of test Enclosure	
	3.3 Instrumentation	
	3.4 Generators/Nozzles	
	3.5 Enclosure Temperature	
	3.6 Test Fires and Programme	
	3.7 Extinguishing System	
	3.8 Procedure	
	3.9 Measurements and observations	
	3.10 Tolerances	
4	Classification criteria	14
	4.1	
5	Test report	15
6	Test method for determination of aerosol generator efficiency coefficient	15
	6.1	

CHAPTER 3

TEST METHOD FOR SYSTEMS OF SHIPS HAVING A LENGTH > 24 M

1	Fire test method for fixed aerosol fire-extinguishing systems of ships having a length L exceeding 24 m	17
1.1	Scope	
1.2	Test method	

CHAPTER 4

TEST METHOD FOR DETERMINATION OF AEROSOL GENERATOR EFFICIENCY COEFFICIENT

1	Test method for determination of aerosol generator efficiency coefficient	19
	1.1 Scope	
2	Method	19
	2.1	
3	Classification Criteria	19
	3.1	

CHAPTER 1 GENERAL REQUIREMENTS FOR APPROVAL

1 General

1.1 Premise

1.1.1 Fixed aerosol fire-extinguishing systems for use in machinery spaces, equivalent to fixed fire-extinguishing systems required by Tasneef Rules, may be accepted on board if Tasneef type approved only.

Systems dealt with in these Rules are also to comply with the applicable requirements given in the specific Tasneef Rules for the vessel where the system will be provided.

The arrangement of the systems on board is subject to the approval of the drawings relevant to the single installation.

Aerosol fire-extinguishing systems consist in the release of a chemical agent to extinguish a fire by interruption of the combustion chemical reaction.

There are two methods for the application of the aerosol agent to the protected space:

- condensed aerosols, which are created in pyrotechnical generators through the combustion of the agent charge; and
- dispersed aerosols, which are not pyrotechnically generated and are stored in containers with carrier agents (such as inert gases or halocarbon agents) with the aerosol released in the space through valves, pipes and nozzles.

1.2 Field of application

1.2.1 General

These Rules apply to fixed aerosol fire-extinguishing systems for use in machinery spaces of ships and yachts (hereafter referred to simply as ships).

- Chapter 1 applies to all ships.
- Chapter 2 applies to ships having a length L not exceeding 24 m and machinery spaces having a gross volume not exceeding 140 m³.
- Chapter 3 applies to ships having a length L exceeding 24m or machinery spaces having a gross volume exceeding 140 m³.

L is the length in metres of the full load waterline measured on the hull plain of symmetry, from the forward side of the stem to the aft side of the sternpost, or transom.

1.2.2 Alternative

As an alternative, at request of the Interested Parties, Tasneef applies the Commission Implementing Regulation (EU) 2020/1170, adopted by the Council on 16 July 2020, if authorized.

including further adoptions, to those ships subject to this Directive.

1.3 Documentation

1.3.1 The request for type approval is to be submitted to Tasneef by the Manufacturer, or by the Applicant if authorized by the Manufacturer, and is to include:

- a) the name of the Manufacturer;
- b) the designation of the system;
- c) a schematic layout of the system;
- d) complete specification of the materials used for all system components;
- e) the installation and maintenance manual;
- f) documentation relevant to previous tests and approvals, if any.

1.4 Issue and validity of the type approval certificate

1.4.1 Subject to the satisfactory outcome of the required checks and tests, Tasneef issues to the manufacturing firm a "Type Approval Certificate" valid for all fixed aerosol fire-extinguishing systems of the same type, dimensions, layout, material, etc as that subjected to type testing. The validity of the certificate is based on the assumption of the constant conformity of the single products manufactured with the satisfactorily tested prototype. The firm is entirely responsible for such conformity. The Type Approval Certificate may be suspended or cancelled by Tasneef when the conditions on which the type approval was based are no longer fulfilled. The Type Approval Certificate is valid for five years from the date of issue.

1.5 Renewal of the type approval certificate

1.5.1 In order to renew the Type Approval Certificate, the documentation in [1.3], is to be submitted to Tasneef with indication of any modifications in respect of the previous approval.

On the basis of the review of such documentation, Tasneef will establish the checks and tests to be carried out in order to renew the Type Approval Certificate.

1.6 Repetition of the tests

1.6.1 Tasneef reserves the right to repeat type tests, wholly or in part, in the case of modification of the Rules on the basis of which the type approval was issued or in the event of doubts or complaints.

2 Definitions

2.1

2.1.1 *Aerosol* is a fire-extinguishing medium consisting of finely divided solid particles of chemicals released into a protected space as either condensed aerosol or dispersed aerosol.

2.1.2 *Generator* is a device for creating a fire-extinguishing medium by pyrotechnical means.

2.1.3 *Efficiency coefficient* is the percentage (%) of aerosol forming composition actually discharged from a specific aerosol generator. It is determined by comparing the mass loss of a generator after discharge to its beginning mass.

2.1.4 *Design application density* (g/m^3) is the mass of an aerosol forming composition per m^3 of the enclosure volume required to extinguish a specific type of fire, including a safety factor of 1.3 times the test density.

2.1.5 Agent-medium for the purpose of these Rules, the terms "agent" and "medium" are interchangeable.

3 Principal Requirements

3.1 General

3.1.1 The design application density is to be determined and verified by the full-scale testing described in the following chapters as applicable.

The delivered density for each type of generator is to be determined and verified by the test method described in the following chapters as applicable.

The system discharge time is not to exceed 120 S. Systems may need to discharge in a shorter time for reasons other than fire-extinguishing.

The quantity of extinguishing agent for the protected space is to be calculated at the minimum expected ambient temperature using the design density based on the net volume of the protected space, including the casing.

The net volume of a protected space is that part of the gross volume of the space which is accessible to the fire-extinguishing agent.

When calculating the net volume of a protected space, this is to include the volume of the bilge, the volume of the casing and the volume of free air contained in air receivers which, in the event of a fire, may be released into the protected space.

The objects that occupy volume in the protected space are to be subtracted from the gross volume of the space. They include, but are not necessarily limited to:

- a) auxiliary machinery;
- b) boilers;
- c) condensers;
- d) evaporators;
- e) main engines;
- f) reduction gears;
- g) tanks; and
- h) trunks.

Subsequent modifications to the protected space that alter the net volume of the space shall require the quantity of extinguishing agent to be adjusted accordingly.

Fire-extinguishing systems which are carcinogenic, mutagenic or teratogenic at application densities expected during use are not permitted.

The discharge of aerosol systems to extinguish a fire could create a hazard to personnel from the natural form of the aerosol, or from certain products of aerosol generation (including combustion products and trace gases from condensed aerosols).

Other potential hazards that should be considered for individual systems are the following: noise from discharge, turbulence, cold temperature of vaporizing liquid, reduced visibility, potential toxicity, thermal hazard and potential toxicity from the aerosol generators, and eye irritation from direct contact with aerosol particles. Unnecessary exposure to aerosol media, even at concentrations below an adverse effect level, and to their decomposition products should be avoided. All aerosols used in fire-extinguishing systems should have non-ozone depleting characteristics.

All systems are to be designed to allow evacuation of the protected spaces prior to discharge through the use of two separate controls for releasing the extinguishing medium. Means are to be provided for automatically giving visual and audible warning of the release of fire-extinguishing medium into any space in which personnel normally work or to which they have access. The alarm is to operate for the period of time necessary to evacuate the space, but not less than 20 s before the medium is released.

Unnecessary exposure to aerosol media, even at concentrations below the adverse effect level, is to be avoided.

Automatic activation of the system may be accepted on a "case-by-case" basis upon the examination of the relevant documentation (electric diagrams, controls, etc.) and, in any case, is admitted for small machinery spaces where personnel cannot have access.

3.2 Condensed aerosol systems

3.2.1 Condensed aerosol systems for normally occupied spaces are permitted in concentrations where the aerosol particulate density does not exceed the adverse effect level as determined by a scientifically accepted technique (see Note 1) and any combustion products and trace gases produced by the aerosol generating reaction do not exceed the

appropriate excursion limit for the critical toxic effect as determined in acute inhalation toxicity test.

Note 1: Reference is made to the United States' EPA's Regional Deposited Dose Ratio Program "Methods of Derivation of Inhalation Reference Concentrations and Application of Inhalation Dosimetry" EPA/600/8-90/066F.

3.3 Dispersed aerosols systems

3.3.1 Dispersed aerosol systems for normally occupied spaces are permitted in concentrations where the aerosol particulate density does not exceed the adverse effect level as determined by a scientifically accepted technique. Even at concentrations below an adverse effect level, exposure to extinguishing agents is not to exceed 5 min. If the carrier gas is a halocarbon, it may be used up to its No Observed Adverse Affect Level (NOAEL) calculated on the net volume of the protected space at the maximum expected ambient temperature without additional safety measures. If a halocarbon carrier gas is to be used above its NOAEL, means are to be provided to limit exposure to no longer than the corresponding maximum permitted human exposure time specified according to a scientifically accepted physiologically based pharmacokinetic (such as PBPK) model or its equivalent which clearly establishes safe exposure limits both in terms of extinguishing media concentration and human exposure time. If the carrier is an inert gas, means are to be provided to limit exposure to no longer than 5 min for inert gas systems designed for concentrations below 43% (corresponding to an oxygen concentration of 12%, sea level equivalent of oxygen) or no longer than 3 min for inert gas systems designed for concentrations between 43% and 52% (corresponding to between 12% and 10% oxygen, sea level equivalent of oxygen) calculated in the net volume of the protected space at the maximum expected ambient temperature.

In no case is a dispersed aerosol system to be used with halocarbon carrier gas concentrations above the Lowest Observed Adverse Effect Level (LOAEL) or at the Approximate Lethal Concentration (ALC); nor is a dispersed aerosol system to be used with an inert gas carrier at gas concentrations above 52% calculated on the net volume of the protected space at the maximum expected ambient temperature, without the use of controls required for CO₂ fire-extinguishing systems by the specific Tasneef Rules for Ships.

3.4 System and components

3.4.1 The system and its components are to be suitably designed to withstand the ambient temperature changes, vibration, humidity, shock, impact, clogging, electromagnetic compatibility and corrosion normally encountered in machinery spaces. Generators in condensed aerosol systems are to be designed to prevent self-activation at a temperature below 250°C.

The system and its components are to be designed, manufactured and installed in accordance with standards accept-

able to Tasneef. As a minimum, the design and installation standards are to cover the following elements:

- a) safety:
 - 1) toxicity;
 - 2) noise, generator/nozzle discharge;
 - 3) decomposition products; and
 - 4) obscuration; and
 - 5) minimum safe distance required between generators and escape routes and combustible materials;
- b) storage container design and arrangement:
 - 1) strength requirements;
 - 2) maximum/minimum fill density, operating temperature range;
 - 3) pressure and weight indication;
 - 4) pressure relief; and
 - 5) agent identification, production date, installation date and hazard classification;
- c) agent supply, quantity, quality standards, shelf life and service life of agent and igniter;
- d) handling and disposal of generator after service life;
- e) pipes and fittings:
 - 1) strength, material properties, fire resistance; and
 - 2) cleaning requirements;
- f) valves:
 - 1) test requirements, and
 - 2) elastomer compatibility;
- g) generators/nozzles:
 - 1) height and area test requirements; and
 - 2) elevated temperature resistance; and
 - 3) mounting location requirements considering safe distances to escape routes and combustible materials;
- h) actuation and control systems:
 - 1) test requirements; and
 - 2) backup power requirements;
- i) alarms and indicators:
 - 1) pre-discharge alarm, agent discharge alarms and time delays;
 - 2) supervisory circuit requirements;
 - 3) warning signs, audible and visual alarms; and
 - 4) announcement of faults;
- j) enclosure integrity and leakage requirements:
 - 1) enclosure leakage;
 - 2) openings; and
 - 3) mechanical ventilation interlocks;
- k) electrical circuits for pyrotechnic generators:
 - 1) requirements for mounting and protection of cables;
- l) design density requirements, total flooding quantity;

Chapter 1

- m) agent flow calculation:
 - 1) verification and approval of design calculation method;
 - 2) fitting losses and/or equivalent length;
 - 3) discharge time;
- n) inspection, maintenance, service and test requirements; and
- o) handling and storage requirements for pyrotechnical components.

The generator/nozzle type, maximum generator/nozzle spacing, maximum generator/nozzle installation height and minimum generator/nozzle pressure are to be within tested limits.

Installations are to be limited to the maximum volume tested.

Where agent containers are stored within a protected space, the containers are to be distributed throughout the space and meet the following provisions:

- a) a manually initiated power release, located outside the protected space, is to be provided. Duplicate sources of power are to be provided for this release and are to be located outside the protected space and be immediately available;
- b) electric power circuits connecting the generators are to be monitored for fault condition and loss of power. Visual and audible alarm are to be provided to indicate this;
- c) pneumatic, electric or hydraulic power circuits connecting the generators are to be duplicated and widely separated. The sources of pneumatic or hydraulic pressure is to be monitored for loss of pressure. Visual and audible alarms are to be provided to indicate this;
- d) within the protected space, electrical circuits essential for the release of the system are to be fire resistant according to standard IEC 60331 or equivalent standards. Piping systems essential for the release of systems designed to be operated hydraulically or pneumatically are to be of steel or other equivalent heat-resisting material to the satisfaction of Tasneef;
- e) each dispersed aerosol pressure container is to be fitted with an automatic overpressure release device which, in the event of the container being exposed to the effects of fire and the system not being operated, will safely vent the contents of the container into the protected space;
- f) the arrangement of generators and the electrical circuits and piping essential for the release of any system are to be such that in the event of damage to any one power release line or generator through mechanical damage,

fire or explosion in a protected space, i.e., a single fault concept, at least the amount of agent needed to achieve the test density can still be discharged having regard to the requirement for uniform distribution of medium throughout the space; and

- g) dispersed aerosol containers are to be monitored for decrease in pressure due to leakage and discharge. Visual and audible alarms in the protected area and on the navigation bridge, in the onboard safety centre or in the space where the fire control equipment is centralized are to be provided to indicate this condition.

The temperature profile of the discharge stream from condensed aerosol generators is to be measured in accordance with the following chapters. This data are to be used to establish the minimum safe distances away from the generator where the discharge temperatures do not exceed 75°C and 200°C.

The casing temperature of condensed aerosol generators is to be measured in accordance with the following chapters. This data are to be used to establish the minimum safe distances away from the generator where the discharge temperatures do not exceed 75°C and 200°C.

Generators are to be separated from escape routes and other areas where personnel may be present by at least the minimum safe distances determined in the two paragraphs above for exposure to 75°C.

Generators should be separated from combustibles by at least the minimum safe distances determined in the two paragraphs above for exposure to 200°C.

The useful life of condensed aerosol generators is to be determined by the manufacturer for the temperature range and conditions likely to be encountered on board ships. Generators are to be replaced before the end of their useful life. Each generator is to be permanently marked with the date of manufacture and the date of mandatory replacement.

The release of an extinguishing agent may produce significant over and under pressurization in the protected space. Constructive measures to limit the induced pressures to acceptable limits are to be provided.

For all ships, the fire-extinguishing system design manual is to address recommended procedures for the control and disposal of products of agent decomposition. The performance of fire-extinguishing arrangements is not to present health hazards from decomposed extinguishing agents (e.g., on passenger ships, the decomposition products are not to be discharged in the vicinity of assembly stations).

Spare parts and operating and maintenance instructions, including operational tests for the system are to be provided as recommended by the manufacturer.

CHAPTER 2

TEST METHOD FOR SYSTEMS OF SHIPS HAVING A LENGTH ≤ 24 M AND WITH MACHINERY SPACES ≤ 140 M³

1 Fire test method for fixed aerosol fire-extinguishing systems of ships having a length L not exceeding 24 m and machinery spaces having a gross volume not exceeding 140 m³

1.1 Scope

1.1.1 This test method is intended for evaluating the extinguishing effectiveness of fixed aerosol fire-extinguishing systems for the protection of machinery spaces of category A.

The test method is applicable to aerosols and covers the minimum requirements for fire-extinguishing.

The test program has two objectives:

- a) establishing the extinguishing effectiveness of a given agent at its tested concentration; and
- b) establishing that the particular agent distribution system puts the agent into the enclosure in such a way as to fully flood the volume to achieve an extinguishing concentration at all points.

2 Sampling

2.1

2.1.1 The components to be tested are to be supplied by the Manufacturer together with design and installation criteria, operational instructions, drawings and technical data sufficient for the identification of the components.

3 Method of test

3.1 Principle

3.1.1 This test procedure is intended for the determination of the effectiveness of different aerosol agent extinguishing systems against spray fires, pool fires and class A fires. It also establishes the minimum safe distances from condensed aerosol generators to personnel and combustible materials.

3.2 Apparatus

3.2.1 Test Room

The test is to be performed in a test room with a gross volume equal, as much as possible, to the maximum volume for which the fire-extinguishing system approval is expected.

The tests are to be performed in a room with a volume between 35, 70 or 140 m³, corresponding to Standard ISO containers 20' or 40': combination of containers with one side deprived to increase the room volume may also be accepted. The test room is to be provided with a closable access door measuring approximately 4 m² in area. Taking into consideration the previously mentioned over and under pressurization the release of an extinguishing medium may produce, suitable means (or procedures) to safely equilibrate the pressure, as well as dissipate the accumulated heat, prior to access again the test room, are to be provided.

3.2.2 Integrity of test Enclosure

The test enclosure is to be nominally leaktight when doors and hatches are closed.

The integrity of seals on doors, hatches and other penetrations (e.g., instrumentation access ports) is to be verified before each test.

3.2.3 Engine/ Bilge Mock-Up

- a) An engine mock-up is to be constructed in steel, plate, thickness at least 3 mm; , with sizes (width x length x height) 1.0 x 1.8 m x 1.4 m. The mock-up is to be fitted with two steel tubes diameter 0.25 m and 1.4 m length, that simulate exhaust manifolds, and a solid steel plate. The top of the mock-up is to provide a 1.35 m tray and a spray (C) is to be placed below the overhanging steel plate on top of the mock-up (see figures 1, 2 and 3 (not in scale)).
- b) a bilge system is to be created by a floor plate system located close to the sides of the engine mock-up with a wall around, fitted to the floor of test room: a fuel trays placed underneath the engine simulate fuel accumulation (hidden pool fire) and open pool fire.
- c) provision are to be made for placement of the fuel trays, as described in table 1, and located as described in figures.

3.3 Instrumentation

3.3.1 Instrumentation for the continuous measurement and recording of test conditions is to be employed. The following measurements are to be made:

- a) temperature of the generator casing;
- b) temperature of the generator discharge stream measured at 0,5 m, 1,0 m and 2,0 m away from the discharge ports;
- c) temperature at three vertical positions (e.g. 1 m, 2,5);
- d) enclosure pressure;
- e) gas sampling and analysis, at mid-room height, for oxygen, carbon dioxide, carbon monoxide and other relevant products;
- f) means of determining flame-out indicators;
- g) fuel nozzle pressure in the case of spray fires;
- h) fuel flow rate in the case of spray fires;
- i) discharge nozzle pressure; and
- j) means of determining generator discharge duration.

3.4 Generators/Nozzles

3.4.1

- a) For test purposes, generators/nozzles are to be located as recommended by the manufacturer.
- b) If more than one generator/nozzle is used, they are to be symmetrically located.

3.5 Enclosure Temperature

3.5.1 The ambient temperature of the test enclosure at the start of the test is to be noted and serves as the basis for calculating the concentration that the agent would be expected to achieve at that temperature and with that agent weight applied in the test volume.

3.6 Test Fires and Programme

3.6.1 Fire Types

The test programme, as described in table 3, should employ test fires as described in Tab 1 below.

Table 1 : Parameters of test fires

Fire	Type	Fuel	Fire size, MW	Remarks
A	76 - 100 mm ID can	Heptane	0.0012 to 0.002	Tell tale
B	0.25 m ² tray	Heptane	0.35	(1)
C	0.70 m ² tray	Diesel/fuel oil	1	(1)
D	3 m ² tray	Diesel/fuel oil	4.4	
E	Low pressure, low flow spray	Heptane 0.03 ± 0.005 kg/s	1.1	
F	Wood crib	Spruce or fir	0.3	(2)
G	0.10 m ² tray	Heptane	0.14	
H	Polymeric sheets	PMMA, Polypropylene, ABS		(3)

(1) Diesel/Fuel oil means light diesel or commercial fuel oil.

(2) The wood crib should be substantially the same as described in standard ISO 14520-1:2006 (Gaseous fire extinguishing systems, Physical properties and system design, Part 1: General Requirements). The crib should consist of six members of trade size 50 mm x 50 mm x 450 mm, kiln dried spruce or fir lumber having a moisture content between 9 and 13%. The members should be placed in 4 alternate layers at right angles to one another. Members should be evenly spaced forming a square structure. Ignition of the crib should be achieved by burning commercial grade heptane in a square steel tray 0.25 m² in area. During the pre-burn period the crib should be placed centrally above the top of the tray at a distance of 300 to 600 mm.

(3) The polymeric sheet test should be substantially the same as described in standard ISO 14520-1:2006 (Gaseous fire extinguishing systems, Physical properties and system design, Part 1: General Requirements).

3.6.2 Test Programme

- a) The fire test programme should employ test fires singly or in combination, as outlined in table 3 below.
- b) All applicable tests of table 3 should be conducted for every new fire-extinguishing media.
- c) Only test 1 is required to evaluate new nozzles and related distribution system equipment (hardware) for systems employing fire-extinguishing media that have successfully completed the requirements of paragraph 3.3.2.2 above. Test 1 should be conducted to establish

and verify the manufacturer's minimum nozzle design pressure.

Table 2 : Spray fire test parameters

Fire type	Low pressure, Low flow (E)
Spray nozzle	Wide spray angle (80°) Full cone type
Nominal fuel pressure	8.5 bar

Fire type	Low pressure, Low flow (E)
Fuel flow	0.03 ± 0.005 kg/s
Fuel temperature	20 ± 5 °C
Nominal heat release rate	1.1 ± 0.1 MW

Table 3 : Test programme

Test No.	Fire combination (see Tab 1)
1	A: Tell tales, 8 corners. (see (1))
2	B: 0.25 m ² heptane tray under mock-up G: 0.10 m ² heptane tray on deck plate located below solid steel obstruction plate Total fire load: 0.49 MW (see (2))
3	C: 0.70 m ² diesel/fuel oil tray on deck plate located below solid steel obstruction plate F: Wood crib positioned as in Fig 2 E: Low pressure, low flow horizontal spray -concealed- with impingement on inside of engine mock-up wall. H: Polymeric sheets positioned as in Fig 2 Total fire load: 3.4 MW (see (3))
4	D: 3 m ² diesel tray under engine mock-up Total fire load: 4.4 MW (see (4))
<p>(1) Tell-tale fire cans should be located as follows:</p> <ul style="list-style-type: none"> • in upper corners of enclosure 150 mm below ceiling and 50 mm from each wall; and • in corners on floors 50 mm from walls; • in case of "double container" test, 12 tell tales are required. <p>(2) In case of "double container" test, B fires are to be ignited in both mock-ups.</p> <p>(3) In case of "double container" test, F and H fires are to be ignited in both mock-ups.</p> <p>(4) In case of "double container" test, D fire is to be ignited in both mock-ups.</p>	

3.7 Extinguishing System

3.7.1 System Installation

The extinguishing system is to be installed according to the Manufacturer's design and installation instructions.

3.7.2 Agent

a) Design density

The agent design density is the net mass of extinguishant per unit volume (g/m³) required by the system Designer for the fire protection application.

b) Test density

The test density of the agent to be used in the fire-extinguishing tests is to be the design density specified by the Manufacturer, except for test 1, which is to be conducted at not more than 77% of the manufacturer's recommended design density.

c) Quantity of aerosol agent

The quantity of aerosol agent to be used is to be determined as follows:

$$W = V \times q,$$

where:

W = agent mass (g);

V = volume of test enclosure (m³);

q = fire-extinguishing aerosol density (g/m³).

3.8 Procedure

3.8.1 Fuel levels in trays

The trays used in the test are to be filled with at least 30 mm fuel on a water base. Freeboard is to be 120 ± 10 mm.

3.8.2 Fuel flow and pressure measurements

For spray fires, the fuel flow and pressure are to be measured before and during each test.

3.8.3 Ventilation

a) Pre-burn period

During the pre-burn period the test enclosure is to be well ventilated. The oxygen concentration, as measured at mid-room height, is to be not less than 20 volume per cent at the time of system discharge.

b) End of pre-burn period.

Doors are to be closed at the end of the pre-burn period.

3.8.4 Duration of test

Doors, ceiling hatches and other ventilation openings are to be closed at the end of the pre-burn period.

Chapter 2

a) Pre-burn time

Fires are to be ignited such that the following burning times occur before the start of agent discharge:

- 1) sprays - 5 to 15 s
- 2) trays - 1 min
- 3) wood crib 3 separate test, one of 2 min, one of 4 min and one of 6 min; and
- 4) polymeric sheets - 210 s.

b) Discharge time

Aerosol agents are to be discharged at a rate sufficient to achieve 100% of the minimum design density in 120 s or less.

c) Hold period

After the end of agent discharge, the test enclosure is to be kept closed for 15 min.

The test is to involve the attempted ignition of two of the tell-tale fire containers. One container is to be at the floor level and the other at the ceiling level at the diagonally opposite corner. At 10 min after extinguishment of the fires, a remotely operated electrical ignition source is to be energized for at least 10 s at each container. The test is to be repeated at one min intervals four more times, the last at 14 min after extinguishment. Sustained burning for 30 s or longer of any of these ignition attempts constitutes a re-ignition test failure.

3.9 Measurements and observations

3.9.1

a) Before test

- 1) temperature of test enclosure, fuel and engine mock-up;
- 2) initial weights of agent containers;
- 3) verification of integrity agent distribution system and nozzles;
- 4) initial weight of wood crib.

b) During test

- 1) start of the ignition procedure;
- 2) start of the test (ignition);
- 3) time when ventilating openings are closed;
- 4) time when the extinguishing system is activated;
- 5) time from end of agent discharge;
- 6) time when the fuel flow for the spray fire is shut off;
- 7) time when all fires are extinguished;
- 8) time of re-ignition, if any, during hold period;
- 9) time at end of hold time
- 10) at the start of the test, initiate continuous monitoring as per [1.3.5], and

11) for condensed aerosol generators:

- temperature of the casing during the fire test and hold time period; and
- temperature profile of the generator discharge stream versus distance away from the discharge ports.

3.10 Tolerances

3.10.1 Unless otherwise stated, the following tolerances are to apply (ref. standard ISO 6182-1:2004):

- a) length $\pm 2\%$ of value;
- b) volume $\pm 5\%$ of value;
- c) pressure $\pm 3\%$ of value;
- d) temperature $\pm 5\%$ of value; and
- e) concentration $\pm 5\%$ of value.

4 Classification criteria

4.1

4.1.1 Class B fires are to be extinguished within 30 s of the end of discharge. At the end of the hold period there is to be no re-ignition upon opening the enclosure.

4.1.2 The fuel spray is to be shut off 15 s after extinguishments. At the end of the hold time, the fuel spray is to be restarted for 15 s prior to reopening the door and there is to be no re-ignition.

4.1.3 The ends of the test fuel trays are to contain sufficient fuel to cover the bottom of the tray.

4.1.4 The wood crib weight loss should be no more than 30% during the 2 min pre-burn test, 50% during the 4 min pre-burn test and 60% during the 6 min pre-burn test.

4.1.5 A re-ignition test is to be conducted after the successful extinguishments of the fires in test 1 in (Fire A) within 30 s after completion of discharge. The test is to involve the attempted ignition of two of the tell-tale fire containers. One container is to be at the floor level and the other at the ceiling level at the diagonally opposite corner. At 10 min after extinguishment of the fires, a remotely operated electrical ignition source is to be energized for at least 10 s at each container. The test is to be repeated at 2 min intervals two more times, the last at 14 min after extinguishment. Sustained burning for 30 s or longer of any of these ignition attempts constitutes a re-ignition test failure.

4.1.6 For the polymeric sheets, the laboratory extinguishing factor for each fuel is that which achieves satisfactory extinguishment of the fire over three successive tests (no flaming 60 s after end of discharge and no re-ignition after 10 min from end of discharge). The design factor is the highest of the laboratory extinguishing factors for the three fuels multiplied by 1.3.

5 Test report

5.1

5.1.1 The test report is to include the following information:

- a) name and address of the test laboratory;
- b) date and identification number of the test report;
- c) name and address of the client;
- d) purpose of the test;
- e) method of sampling system components;
- f) name and address of the Manufacturer or Supplier of the product;
- g) name or other identification marks of the product;
- h) description of the tested product:
 - 1) drawings;
 - 2) descriptions;
 - 3) assembly instructions;
 - 4) specification of included materials; and
 - 5) detailed drawing of test set-up;
- i) date of supply of the product;
- j) date of test;
- k) test method;
- l) drawing of each test configuration;
- m) identification of the test equipment and used instruments;
- n) conclusions;
- o) deviations from the test method, if any;
- p) test results including measurements and observations during and after the test; and
- q) date and signature.

6 Test method for determination of aerosol generator efficiency coefficient

6.1

6.1.1 The test is to be carried out in accordance with Chapter 4.

Figure 1




Figure 2





Figure 3



CHAPTER 3 TEST METHOD FOR SYSTEMS OF SHIPS HAVING A LENGTH > 24 M

1 Fire test method for fixed aerosol fire-extinguishing systems of ships having a length L exceeding 24 m

1.1 Scope

1.1.1 This test method is intended to evaluate the extinguishing effectiveness of fixed aerosol fire-extinguishing

systems for the protection of machinery spaces of ships having a length exceeding 24 m, or having machinery spaces with a volume exceeding 140 m³.

1.2 Test method

1.2.1 The test is to be carried out in accordance with IMO MSC.1/Circ.1270 and MAC.1/Circ.1270/Corr.1.

CHAPTER 4

TEST METHOD FOR DETERMINATION OF AEROSOL GENERATOR EFFICIENCY COEFFICIENT

1 Test method for determination of aerosol generator efficiency coefficient

1.1 Scope

1.1.1 This test method is intended for measuring the mass of aerosol forming composition that is actually discharged by a fixed aerosol generator.

1.1.2 The test method is applicable to condensed aerosols.

1.1.3 The objective of the test programme is to establish the difference between the total mass of aerosol forming composition in the generator and the mass of composition that is discharged.

2 Method

2.1

2.1.1 The mass of aerosol forming composition in each type generator should be specified by the manufacturer..

2.1.2 The gross weight of each type generator should be determined by weighing on a laboratory scale.

2.1.3 An average of five generators should be discharged in an appropriate facility. After the generators have cooled, the average net weight of the empty generators should be determined using the same laboratory scale used in paragraph [2.1.2] above.

3 Classification Criteria

3.1

3.1.1 The efficiency coefficient (%) should be determined by subtracting the average weight of the generator after discharge from the weight prior to discharge and dividing by the manufacturer's stated mass of aerosol forming composition.